



CHANDLER FIRE DEPARTMENT
PLAN REVIEW GUIDE FOR SITE PLANS



PROJECT NAME: _____ CITY LOG #: _____
PROJECT ADDRESS: _____ CONTRACTOR: _____
CONTACT PERSON: _____ TELEPHONE #: _____

Site plans submitted for review and approval shall contain the following information. Place your initials beside each statement to indicate necessary information is included. Place N/R after any item not required by the fire code. Place N/A after any item not applicable. **A review will not be conducted without the guide being submitted with the drawings.**

1. Fire Department "General Notes to the Contractor" are provided on the plan.
2. Required fire lanes, emergency access roadways, and emergency vehicle turnarounds are outlined and dimensions are marked and identified on the drawing.
3. Fire lane sign locations and the sign detail are shown on the drawing.
4. Any gates or other barriers limiting 24-hour access to the site are shown on the plans. Key Switch & Pre-emption location are shown on the plans.
5. On site fire hydrants are required when any point of the first floor exterior wall of a building, 12,000 square feet or less is more than 300 feet from a public fire hydrant, OR any point of the first floor exterior wall of a building, larger than 12,000 square feet is more than 150 feet from a public fire hydrant.